

	<h2>Addressable Manual Call Point</h2> <h3>AW-D305</h3> <h3>Date Sheet</h3>
Operating Voltage	Signal Loop 24V(18V~28V) Power 24VDC(20VDC~28VDC)
Standby Current	Loop<0.8mA ; Power<2mA
Action Current	Loop<5mA ; Power<15mA
Output Capacity	1A@DC30V
Input Mode Setting	NC or NO input mode can be set by the jumper JP4.
Programming Method	Electronically addressed
Code Range	One address within 1~324.
Indicators	Inspection indicator: I blink once about every 12 seconds in the inspection status or remain lit in the output status; Input indicator : remain lit in the feedback status.
Operating Temperature	-10℃~+55℃
Relative Humidity	≤95% , non-condensing
Material of Enclosure	ABS
Dimension (L×W×H)	86mm×86mm×41mm (with base)
Mounting Hole Distance	60.5mm
Weight	About 148g (with base)
Operating Voltage	Signal Loop 24V(18V~28V) Power 24VDC(20VDC~28VDC)
Certificate	  <p>0832-CPR-F2510 1426d/01</p>



ASENWARE LTD
 ADDRESS: 6 PROSPECT WAY, ROYAL OAK INDUSTRIAL ESTATE DAVENTRY,
 NORTHAMPTONSHIRE, ENGLAND, NN118PL
 WEBSITE: www.asenware.com EMAIL: info@asenware.com